

Certified Validation Report: Provided by Validator

Audit Information:

Water Supplier Name: **El Segundo** PWS ID: **1910040**
System Type: **Potable** Audit Period: **Calendar 2017**
Utility Representation: **Lucienne Cummings, Anthony Esparza**
Validation Date: **June 6th, 2019** Call Time: **11:00 AM** Sufficient Supporting Documents Provided: **Yes**

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: **67** Data Validity Band (Level): **Band III (51-70)**

ILL: **0.02** Real Loss: **0.27 gallons/connection/day** Apparent Loss: **16.82 gallons/connection/day**

Non-revenue water as percent of cost of operating system: **0.8%**

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

If not, rejected recommendations are included here.

Validator Information:

Water Audit Validator : **Aretha Samuel** Qualifications: **Water Audit Validator Certificate issued by the CA-NV Section of the AWWA**

Validator Provided

Water Supplier Name: City of El Segundo.

Water Supplier ID Number: 1910040

Water Audit Period: Calendar 2017

Water Audit & Water Loss Improvement Steps:

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

1. Steps taken to improve the water imported numbers by removing the water violation acre feet from the water imported sheet.
2. Meter replacement for the oldest meters conducted to improve billed meter numbers.
3. Conducted customer meter testing for some old and new meters.

Utility Provided

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (Print)

Executive Position

Signature

Date

Ken Berkman

Director of Public Works

Anthony Esparza

FOL:
Water Division Supervisor for Ken Berkman
8/25/21